

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

November 18, 2008

GORILLA PVC CEMENT LLC J.KEITH COURTWAY PO BOX 848969 HOLLYWOOD FL 33084

Re: Description: SOLVENT CEMENT

Manufacturer: GORILLA PVC CEMENT LLC Product Name: GORILLA PVC CEMENT Model Number(s): GORILLA PVC CEMENT

Product File No: 20080627

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.40 (14) (b) 1. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

This product may be used on PVC water service and DWV pipe without primer.

This approval supersedes the approval issued on February 7 2004 under product file number 20040015.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040015.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742

Fax: 608-267-9566

E-mail: Jerry.Thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 08062701.DOC